

Bilfinger Industrial Services Polska Sp. z o.o.
ul. Pożarowa 6, 03-309 Warszawa, Polska



BILFINGER

Engineering & Maintenance

Warszawa, 2020.03.31.

Reference letter

In connection with the dewatering service of the transformer oil type Nytro Taurus (produced by Nynas), in the transformer block no. 2 -121/15,75/6,3 kV (power 50/40/40 MVA) in the Żerań Thermal Power Plant the company Bilfinger Industrial Services Polska used dewatering unit OPS 010 produced and delivered by the ARGO-HYTOS Polska company.

During the service work, which lasted 2.5 weeks, a volume of about 27 tons of oil was filtered. The tested parameter, on the basis of which the improvement of fluid quality was evaluated, was breakdown voltage. The tests confirmed that the OPS 010 unit led to a significant improvement of this parameter. The breakdown voltage of tested oil increased from initial value of 26 kV to 60 kV.

Due to the high dewatering efficiency of the OPS 010 unit and professional technical and logistic support throughout the entire period of service work, we recommend ARGO-HYTOS Polska as a reliable and experienced partner in works related to dewatering of transformer oils.

Kierownik Wydziału Elektrycznego i AKPiA
Centrum Serwisowe Warszawa

Jacek Kaczmarek

Region Continental Europe

**Bilfinger Industrial Services
Polska Sp. z o.o.**
ul. Pożarowa 6
03-309 Warszawa
Polska

Telefon +48 22 34 09-100
Fax +48 22 34 09-280
sekretariat.is-polska@bilfinger.com
www.is-polska.bilfinger.com

Centrala i siedziba spółki
Warszawa
Sąd Rejonowy dla m.st. Warszawy,
XIII Wydział Gospodarczy
Krajowego Rejestru Sądowego
KRS 0000138008
Regon 015252900

Zarząd
Leszek Jankowski – Prezes Zarządu

Konto bankowe
mBank S.A.
Konto 96114010100000587612001001
IBAN PL 96114010100000587612001001
SWIFT-Code BREXPLPWWA1

VAT UE PL5213218636
NIP 521 32 18 636
Urząd Skarbowy w Warszawie